

	Name of Work: Internal rewiring
The Principal / Teacher-In-Charge	Vidyasagar College; Kolkata (
Vidyasagar College	installation including replacement
17, Bidhan Sarani Lane	Kolkata-700006
Kolkata-700006	

Sl. No.	Descriptions	Unit	Qty
1	Dismantling the existing old damage light point / circuit / submain all sizes from its original position in different light point etc as required.	Job	1
2	Wiring for light point / fan point with 1.5 sqmm PVC insulated PVC sheathed copper single core cable in surface PVC conduit pipe / PVC casing batten with piano type switch wooden board high lamp sheet cover complete the connection etc as required (Long Point).	Nos.	68
3	Wiring for circuit wiring with 1.5 sqmm PVC sheathed PVC insulated single core copper cable in surface PVC conduit pipe with copper earthing wire including 2 core 1.5 sqmm PVC copper in the PVC conduit pipe etc as required	Mtrs.	180
4	Wiring for circuit wiring with 2.5 sqmm PVC sheathed PVC insulated single core copper cable in surface PVC conduit pipe with copper earthing wire including 2 core 2.5 sqmm PVC copper in the PVC conduit pipe etc as required	Mtrs.	100
5	Wiring for submain wiring with 6 sqmm PVC sheathed PVC insulated single core copper cable in surface 25 sqmm PVC conduit pipe with copper earthing wire including 6 sqmm X 4 core PVC copper cable in the PVC conduit pipe etc as required.	Mtrs.	130
6	Supply and fixing 15Amps power plug board with 15Amps switch (3 nos.) with 15Amps 5 pin plug (3nos.) socket including 8" X 12" wooden switch board on high lamp sheet cover in all accessories surface power board complete etc as required.	Nos.	9
7	S/F of following way single pole and neutral sheet steel MCB DB 240 Volt on surface complete the earthing etc as required (but without MCB / Isolator) a) 12 way DB box	No.	1
8	S/F of following size 6Amps to 32Amps rating 240 Volt S.P. MCB complete the connectin etc as required	Nos.	12
9	S/F of following rating, TP 240 Volt isolator in the existing MCB DB complete with connection etc as required. 63 Amps TP	Nos.	2
10	Supply of surface / pendant mountain type prewired box type florecent fittings suitable for linier florecent Fittings with double tube light complete with down rod including all accessories etc as required.	Nos.	20
11	S/F of following size power plg switch box with 15Amps plug with stater with PVC switch box only for A.C line 3 pin plug with top complete etc as required.	Nos.	3
12	Dismantling and refixing 60 inch A.C ceiling fan with long size down rod supply and fixing M S fan clamp with all accessories etc as required.	Nos.	8

Last date of tender - 1st June 2016

Place - Drop box placed at Vidyasagar College, 39, Sankar Ghosh Lane, Kolkata-700006 from 12pm to 4.30 pm

Antan Kundu

Principal
Vidyasagar College
Kolkata - 700006