



VIDYASAGAR COLLEGE

NAAC ACCREDITED

39, SANKAR GHOSH LANE, KOLKATA - 700 006
PHONE : (Principal) - (033) 2241-3018 (Office) : (033) 2241-4447

● Website : www.vidyasagarcollege.edu.in ● E-mail : vidyasagarcollegekolkata@gmail.com

Ref. No. VC/T/OFF/09/2019-2020

Date: 31.05.2019

Sealed quotation are invited from Competent vendor (Electrical) with in 7 days from this notice for "Electrical Wiring Job".

SL	DESCRIPTION OF ITEM	QTY
1	Wiring for light point /fan point with 1.5 sqmm PVC insulated PVC shethed copper single core cable in surface /recessed PVC conduct pipe/PVC casing batten with piano type switch board highlam sheet cover complete the connection etc. as required	33 Point
2	Wiring for circuit wiring with 1.5 sqmm PVC shethed PVC insulated single core copper cable in surface PVC conduit pipe with copper earthing wire including 2 core 1.5 sqmm PVC copper in the PVC conduit pipe etc as required	50 Mtr.
3	Wiring for circuit wiring with 2.5 sqmm PVC shethed PVC insulated single core copper cable in surface PVC conduit pipe with copper earthing wire including 2 core 2.5 sqmm PVC copper in the PVC conduit pipe etc as required.	95 Mtr.
4	Wiring for sub main line wiring with 6 sqmm x 2 core PVC shethed PVC insulated single core copper cable in surface recessed PVC conduit pipe with copper earthing wire including all accessories etc as required.	50 Mtr.
5	Supply and fixing 15 amp power plug board with 15 amp switch (3 Nos.) with 15 amp 5 pin plug (3 Nos.) socket including 8" x 12" wooden switch board on hilaam sheet cover in all accessories surface power board complete etc as required.	2 No.
6	Supplying & fixing 8" x 6" size wooden box with hilaam sheet board cover for power switch box including supply of 5A 5 Pin-3 Nos. Plug socket-3 Nos, with 5 A switch with all accessories etc as required.	15 No.
7	Supplying and fixing of following way single pole and neutral sheet steel MCB DB 240 V on surface complete the earthing etc as required (but without MCB/Isolator 2 x 6 way DB Box)	2 No.
8	Supplying and fixing of following size 6 AMP to 32 AMP rating 240V SP MCB complete the connection etc as required.	12 Nos.
9	Supplying and fixing of following DP 240V Isolator in the existing MCB DB complete DP with connection etc as required 32 AMP DP.	2 No.

The quotation must be address to the Principal, Vidyasagar College, to be submitted in the drop box at 39, Sankar Ghosh Lane, Kolkata -700006 before 6th june,2019 (before 4 PM)

By order